FIRE SERVICE LICENSE

"WE SERVE TO SAVE 100 Years (1908 - 2008)"

(Under Section 13 of the Tamil Nadu Fire Service Act 1985 and with Tamil Nadu Fire Service Rules 1990 – Appendix - III)

LICENCE NO. 94/2021 K. Dis. No. 2522/C1/2021. DATE:- 16.04.2021.

License is hereby granted under section 13 of the Tamil Nadu Fire Service Act 1985, for Running SASTHAA POLYTECHNIC COLLEGE (G + 2) (height 36 feet) (Mention whichever is applicable) Within the Jurisdication of Keelanilaikkottai Panchayat at the Permises S.F.No: 281, Karaikudi – Aranthangi Main Road, Keelanilaikkottai, Thirumayam Taluk, Pudukkottai District. Subject to the following conditions noted there on and such other conditions as may be prescribed. The above said premises was inspected by The Station Officer Thirumayam on 18.03.2021. The Period of Validity of this License shall be from 16.04.2021 to 15.04.2022.

CONDITIONS

As per Col. 13 of Appendix V to the Rules Under Section 13 of the Act.

- 1. All the Fire Extinguishers have to be recharged and maintained periodically as per code I.S. 2190 / 2010
- 2. Down comer with 10000 Ltr Capacity of overhead tank should be provided and it should be maintained well.
- 3. Fire Pump with 450 LPM should be provided and it should be maintained well.
- 4. Hose Reel Assembly system should be provided and it should be maintained well.
- 5. Register of Fire Extinguisher and Register of Mock Drill Should be maintained as per form II & III respectively.
- 6. Off site (Emergency) Mock Drill should be conducted every year.
- 7. Elementary Fire Fighting Training should be given to the employee from fire service department.
- 8. A Board bearing the phone number of the fire and rescue station should be displayed in the premises.

9. House Keeping should be neet and clean.

10. If there is any deviation from the Govt. Rules and Act the License issued will be cancelled without any notice.

(Office Seal With date)

1 6 APR 2021

District Officer,

Fire & Rescue Service, Pudukkottai District,

Pudukkottai

To

The Chairman

Sasthaa Polytechnic Coffege,

S.F.No: 281, Karaikudi - Aranthangi Main Road,

Keelanilaikkottai, Thirumayam, Taluk,

Pudukkottai District.

Copy to :- Deputy Director, Central Region, Trichy.